

From: Price, Steven [mailto:Steven.Price@illinois.gov]
Sent: Wednesday, June 26, 2013 10:37 AM
To: 'Joshua Knight'
Cc: Robinson, Stephen A; Lackey, Scott A; jmorecraft@edgarcountyhighway.org; 'Mark R. Isaf'; 'Aaron Lawson'
Subject: RE: Zimmerly Ready Mix

From **May 29th** until 1:00pm on **June 25th** Zimmerly Ready-mix **did not have an approved freeze-thaw coarse aggregate**. Zimmerly Ready-mix **was made aware of this on May 29th**. Due to not having an approved freeze-thaw coarse aggregate Zimmerly Ready-mix **did not have an approved SI mix design that would meet the requirements of Standard Specification 1004.02 (f)**. Therefore, on June 17th Zimmerly Ready-mix did not have an approved SI mix that would meet the requirements of Standard Specification 1004.02 (f). The Zimmerly Ready-mix plant in Paris is an approved IDOT plant. On June 24th Zimmerly Ready-mix received shipment of an approved freeze-thaw coarse aggregate. On the morning of **June 25th** Zimmerly Ready-mix (Zach Patrick) submitted a SI,PV mix design to me for approval. I reviewed the mix and approved it. **On June 25th at 1:00pm I hand delivered the approved SI,PV mix design to Zach Patrick.**